



PRODUCTS TYPE	CODE	STANDART	
Hot Dip Galvanised	HDG	EN ISO 1461	
Hot Dip Pregalvanised	PG	EN 10346	
Electro Galvanised	EG	TS 149	
Stainless Steel 304 Grade	304	AISI 304	
Stainless Steel 316 Grade	316	AISI 306	
Electrostatic Powder Paint	FSR	RAL CODES	











ARDIC DATASHEET

PRODUCTS RANGE	HDG	PG	EG	304	316	ESB
Standart Cable Trays	ok	ok	ok	ok	ok	ok
Return Falnged Cable Trays	ok	ok	ok	ok	ok	ok
Light Duty Cable Ladders	ok	ok	ok	ok	ok	ok
Medium Duty Cable Ladders	ok	ok	ok	ok	ok	ok
Heavy Duty Cable Ladders	ok	ok	ok	ok	ok	ok
Marine Cable Ladders	ok	ok	ok	ok	ok	ok
Marine Cable Ladders	ok	ok	ok	ok	ok	ok
Cable Trunkings	ok	ok	ok	ok	ok	ok
Underfloor Cable Trunkings	ok	ok	ok	ok	ok	ok
C Channels and Profiles	ok	ok	ok	ok	ok	ok


## Technical Details / Teknik Detaylar







W



## Ağır Hizmet Kablo Kanalı W150mm H100mm T1,2mm L:3000 HDG

DIMENSIONS				
Genişlik	Yükseklik	Kalınlık	Kaplama	Perfore
150mm	100mm	1,2mm	Sıcak Daldırma	Delikli





# **CABLE TRAYS - GENERAL INFORMATION**

Recommended Conditions for Stocking & Handling of Cable Trays and Cable Ladder Systems

Avoid stocking and shipping in humid or wet conditions. Dry environment is required for all metal components. Always, however, enable the items have air in-take at all times.

Keep all components away from the risk of physical impacts. Preferably all items be kept in original packages, and it is strongly recommended to store on pallets and/or in cardboard boxes. Goods are palletized and shrink wrapped with secure PVC straps in export packaging.

System components must not be used as walkway or support unit for people as since such behavior may reduce the performance of the components where as it also may cause personal injury and harm the entire electrical system.

All parts must be controlled for any burrs or irregularities that may harm cables, equipments or workers. Protective gloves and caps must be worn during carrying and installing of cable trays or cable ladders.

In case that any damage is detected in the system components, immediate precautions must be taken.

All cable trays / cable ladders must be connected each other at the ends by straight connectors.

Installation of cable tray & cable ladder systems must be performed by qualified personnel.

Loading Capacity Graphs must be taken in consideration in electrical projects and installations.

### **ANTI-CORROSION**

The corrosive environment of the site must be studied prior to the determination of the material and finish options.

Taking into account below data, the proper selection will lengthen the life of cable tray system and provide safe and economical use.

We suggest pregalvanised finish in dry and indoor conditions; whereas in humid and outdoor conditions hot dip galvanisation must be used.

### **CLASSIFICATION OF ENVIRONMENTS**

Corrosion category	Loss of thickness	Typical environment		
	μm/year	Outdoor	İndoor	
C1 inconsiderable	>0,1	-	Heated buildings (offices, schools, stores etc.)	
C2 Slight	>0,1 until 0,7		Not heated buildings with formation of condensate like store houses, coliseums	
C3 Moderate		City and industrial environments with moderate pollution	Highly humid production plants like laundry, brewery and diary	
C4 Strong	Service 24 Delay Tourist Tourist	Industrial areas and coastlines with moderate salt impact	Chemical plants, swimming pools	
C5-I Very strong (industrial)	AND ALICE SECOND CONTROL OF THE PARTY OF THE	Industrial environment with high humidity and aggressive atmosphere	Buildings or areas with almost permanent condensation and pollution	
C5-M Very strong (marine)		10000	Buildings or areas with almost permanent condensation and pollution	

ARDIC ELEKTRIK SAN. VE TIC. LTD. STI.

1 www.ardic.com